

346

xx

In replying please quote No.  
and date of this letter.

Valid upto 06 JUL 2015

**Information of Disapproval under Section 346 of the Mumbai  
Municipal Corporation Act, as amended up to date.**

No. B.B./CE/

BS/A

of 20 - 20

**MEMORANDUM****CE / 5225 / BPEC / AT 07 JUL 2014**

Municipal Office,


Mumbai ..... 20

**M/s. Nayan Builders, C.A. to owner**

With reference to your Notice, letter No. .... 6779 dated ..... 17.10.2013 ..... 20 and delivered on ..... 20 and the plans, Sections, Specifications and Descriptions and further particulars and details of your buildings at ..... Proposed building on plot bearing C.T.S. No. 1391, 1391/1 & 1/2 ..... and further particulars and details of your buildings at ..... of village ..... Mulyad (West) at J.N. Road, MURUND (West), Mumbai ..... 20 ..... furnished to me under your letter, dated ..... 20 ..... I have to inform you that I cannot approval of the building or work proposed to be erected or executed, and I therefore hereby formally intimation to you, under Section 346 of the Bombay Municipal Corporation Act as amended upto-date, my disapproval by thereof reasons :-

**(A) CONDITIONS TO BE COMPLIED WITH BEFORE STARTING  
THE WORK BEFORE PLINTH C.C.**

1. That the commencement certificate under Sec.45/69(1)(a) of the M.R&T.P. Act will not be obtained before starting the proposed work.
2. That the compound wall is not constructed on all sides except on road side of the building of the plot clear of road widening line with foundation below the bottom of road side drain without obstructing the flow of rain water from the adjoining holding to prove possession of holding before starting the work as per D.C. Regulation No.38(27).
3. That the low lying plot will not be filled up to reduced level of at least 92 T.H.D. or 6" above adjoining road level whichever is higher with murum, earth, boulders, etc. and will not be leveled, rolled, consolidated and sloped towards road side before starting the work.
4. That the specification for layout/D.P./or access roads/development of setback land will not be obtained from Executive Engineer (Road Construction) before starting the construction work and the access and setback land will not be developed accordingly including providing street lights and S.W.D., the completion certificate will not be obtained from Executive Engineer (R.C.)/Executive Engineer (S.W.D.) E.S. before submitting building completion certificate.



07/07/14  
Executive Engineer Building Proposal  
(Eastern Suburbs.)

( ) That proper gutters and down pipes are not intended to be put to prevent water dropping from the eaves of the roof on the public street.

( ) That the drainage work generally is not intended to be executed in accordance with the Municipal requirements.

Subject to your so modifying your intention as to obviate the before mentioned objections and meet by requirements, but not otherwise you will be at liberty to proceed with the said building or work at anytime before the ..... day of 6 JUL 2015, but not so as to contravene any of the provision of the said Act, as amended as aforesaid or any rule, regulations or bye-law made under that Act at the time in force.

Your attention is drawn to the Special Instructions and Note accompanying this Intimation of Disapproval.

TA 1, 2398 \ 2052 \ 32  
Executive Engineer, Building Proposals,  
Zone E.S-II & IV Wards.

Two of A.C. 2198/B MSW.M.2/M

### SPECIAL INSTRUCTIONS

E.O.S.G.I.S! 2052

(1) THIS INTIMATION GIVES NO RIGHT TO BUILD UPON GROUND WHICH IS NOT YOUR PROPERTY. VI of I(1961), 1971, M.2.T.C. granted doig no gaibuidh baoqorP

(2) Under Section 66 of the Bombay Municipal Corporation Act, 1961, the Municipal Commissioner for Greater Mumbai has empowered the City Engineer to exercise, perform and discharge the powers, duties and functions conferred and imposed upon and vested in the Commissioner by Section 345 of the said Act.

(3) Under Byelaw, No. 8 of the Commissioner has fixed the following levels :—

"Every person who shall erect as new domestic building shall cause the same to be built so that every part of the plinth shall STAND AT LEAST 3 FEET ABOVE THE GROUND LEVEL WITH COMFORTABLE SPACES ON ALL SIDES TO BE PROVIDED AS PER THE FOLLOWING TABLE :—

(a) Not less than, 2 feet (60 cms.) above the level of the adjoining street at the nearest point at which the drain from such building can be connected with the sewer then existing or thereafter to be laid in such street."

(b) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

(c) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

(d) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

(e) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

(f) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

(g) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

(h) Not less than 2 feet (60 cms.) above the ground portion of the ground, within 5 feet (160 cms.) of such building.

Attention is drawn to the note accompanying this Intimation of Disapproval.

**BRIHANMUMBAI MANDALAGAR PALIKA**  
**CE / S225 / BPES / AT 107 JUL 2014**

5. That the Licensed Structural Engineer will not be appointed, supervision memo as per appendix XI Regulation 5(3)(IX) will not be submitted by him.
6. That the structural design and calculations for the proposed work considering seismic forces as per I.S.Code Nos.456-2000, 13920 - 1993, 4326 and 1893 - 2002 as per circular u.no.CE/PO/11945/1 dated 2.2.2006 for existing building showing adequacy thereof to take up additional load will not be submitted by him.
7. That the regular/sanctioned/ proposed lines and reservations will not be got demarcated at site through A.E.(Survey)/E.E.(T&C)/ E.E.(D.P.)/ D.I.L.R. before applying for C.C..
8. That the registered undertaking and additional copy of plan shall not be submitted for agreeing to hand over the setback land free of compensation and that the setback handing over certificate will not be obtained from Ward Officer and the ownership of the setback land will not be transferred in the name of M.C.G.M.
9. That the Indemnity Bond indemnifying the Corporation for damages, risks, accidents, etc. and to the occupiers and an undertaking regarding no nuisance will not be submitted before C.C./starting the work.
10. That the existing structure proposed to be demolished will not be demolished or necessary phase programme with agreement will not be submitted and got approved before C.C.
11. That the requirements of N.O.C. of concerned Electric Supply Co. will not be obtained and the requisitions, if any, will not be complied with before occupation certificate/B.C.C.
12. That the qualified / registered site supervisor through architect/structural engineer will not be appointed before applying for C.C.& his name and license No. duly revalidated will not be submitted.
13. That the extra water and sewerage charges will not be paid to Asst.Engineer, Water Works, 'T' Ward before C.C.
14. That adequate care in planning, designing and carrying out construction will not be taken in the proposed building to provide for the consequence of settlement of floors and plinth filling etc.
15. That adequate care will not be taken to safeguard the trees existing on the plot while carrying out construction work & remarks from S.G. shall not be submitted.
16. That the notice under Sec.347 (1)(a) of the Mumbai Municipal Corporation Act will not be sent for intimating the date of commencement of the work.
17. That this office will not be intimated in prescribed proforma for checking the opens spaces and building dimensions as soon as the work upto plinth is completed.
18. That the clearance from Assessment Department regarding upto date payment of municipal taxes will not be submitted.
19. That the requirement of bye law 4(C) will not be complied with before starting the drainage work and in case Municipal sewer is not laid, the drainage work will not be carried on as per the requirement of Executive Engineer (Sewerage Project).

  
Executive Engineer Building Proposal  
(Eastern Suburbs, A-II)

BRIHADMUMBAI MAHAHAGARPALIKA

CE / 522S / BPES / AT 07 JUL 2014

20. That the copy of Intimation of Disapproval conditions & other layout or sub division conditions imposed by the Corporation in connection with the developmental at site shall not be given to the would be purchaser and also displayed at site.
21. That the N.A. permission from the Collector of Bombay shall not be submitted.
22. That a Janata Insurance Policy or policy to cover the compensation claims arising out of Workmen's Compensation Act 1923 will not be taken out before starting the work and will not be renewed during the construction of work.
23. That the development charges as per M.R.T.P.(amendment) Act 1992 will not be paid.
24. That the carriage entrance shall not be provided before starting the work.
25. That the registered undertaking in prescribed proforma agreeing to demolish the excess area if constructed beyond permissible F.S.L. shall not be submitted before asking for C.C.
26. That the adequate & decent temporary sanitary accommodation will not be provided for construction workers on site before starting the work.
27. That the documentary evidence regarding ownership, area and boundaries of holding is not produced by way of extracts form the District Inspector of Land Records, extracts from City Survey Record and conveyance deed etc.
28. That separate P.R. Cards for each sub-divided plots, road etc. for exhibiting area in words & figures etc. will not be submitted.
29. That the debris will not be removed before submitting the building completion certificate and requisite deposit will not be paid before starting the work towards faithful compliance thereof.
30. That the No Objection Certificate from Hydraulic Engineer for the proposed development will not be obtained and his requirements will not be complied with.
31. That the registered undertaking agreeing to form Co-op. Housing society will not be submitted before starting the work.
32. That the society will not be formed & got registered and true copy of the registration of society will not be submitted.
33. That the proposal will contravene the section 251 (A)(A) of the Mumbai Municipal Corporation Act.
34. That the remarks from Asst. Engineer, Water Works regarding location, size capacity of the suction tank, overhead storage tank for proposed and existing work will not be submitted before starting the work and his requirements will not be complied with.
35. That the capacity of overhead tank will not be provided as per 'P' form issued by department of Hydraulic Engineer and structural design to that effect admitted before requesting to grant commencement certificate.
36. That the phase programme for infrastructure development will not be submitted and got approved and will not be developed as per phase programme.
37. That the undertaking for paying additional premium due to increase in land rate as and when demanded shall not be submitted.

  
Executive Engineer Building Proposals  
(Eastern Suburbs.) - II

BRIHANMUMBAE MAMAHAGARPALIKA  
CE / 5225 / BPES / AT 107 JUL 2014

39. That the N.O.C. from Insecticide Officer shall not be submitted.
39. That the board mentioning the name of Architect/Owner shall not be displayed on site.
40. That the requirements as per circular no. CE/PD/12387 of 17.3.2005 shall not be complied with during the execution of work.
41. That the necessary remarks for training of nalla /construction of S.W.D. will not be obtained from Dy.Ch.E.(S.W.D.)City & Central cell, before plinth C.C. and compliance of said remarks will not be insisted before granting full C.C. for the building.
42. That the debris management plan shall not be submitted to S.W.M. Department.
43. That the C.C. shall not be asked unless payment of advance for providing treatment at construction site to prevent epidemics like Dengue, Malaria etc. is made to the Insecticide Officer of the concerned ward office and provision shall not be made as and when required by Insecticide Officer for inspection of water tanks by providing safe and stable ladder, etc. and requirements as communicated by the Insecticide Officer shall not be complied with.
44. That the registered U/T shall not be submitted by owner / developer / builder to sale the tenements / flats on carpet area basis only and abide by the provisions of Maharashtra Ownership flats (Regulation of promotion of construction, sale, Management & Transfer) Act; (MOFA) amended upto date. Indemnity Bond indemnifying M.C.G.M. and its officers from any legal complications arising due to MOFA shall not be submitted.
45. That the remarks from the existing road shall not be submitted from A.E. (Maint.) T/W Ward.
46. That the registered U/T stating that owner / developer will not object in future for development of adjoining plot whenever they come forward for development, which may involve deficient open space and the clause to that effect will be incorporated in sale agreement.
47. That the registered undertaking stating that the clause incorporating in sale agreement for purchaser informing building under reference is condoned with deficient open space of they will not object the society.
48. That the work of construction shall not be carried out between 7.00 a.m. to 7.00 p.m.
49. That the architect shall not submit the quarterly progress report of the proposed work.
50. That the debris generated / building material will not be dumped within a periphery of 50.00 Mtrs. from mangroves.
51. That the Title Clearance Certificate for this property under reference issued by solicitor shall not be submitted.
52. That all the structural members below the ground shall not be designed considering the effect of chlorinated water, sulphur water, seepage water etc. and any other possible chemical effects and due care while constructing the same will be taken and completion certificate to that effect shall be insisted before granting further C.C. beyond plinth from the licensed Structural Engineer.
53. That the revised NOC from Railway shall not be submitted for the proposed development.

  
07/07/14,  
Executive Engineer Building Proposed  
(Eastern Suburbs.) - [ ]

**BRIHANMUMBAI MAHARAGARPALIKA**  
**CE / 5225 / BPES / AT : 87 JUL 2014**

- B) CONDITIONS TO BE COMPLIED WITH BEFORE FURTHER C.C.**
1. That the N.O.C. from Civil Aviation Department will not be obtained for the proposed height of the building.
  2. That the railway reservation, road will not be handed over before asking C.C. beyond 50% potential.
- C) GENERAL CONDITIONS TO BE COMPLIED WITH BEFORE O.C.**
1. That some of the drains will not be laid internally with C.I. pipes of adequate size.
  2. That the dust bin will not be provided as per C.E.'s circular No.CE/9296/11 of 26.6.1978.
  3. That the surface drainage arrangement will not be made in consultation with Executive Engineer (S.W.D.) or as per his remarks and a completion certificate will not be obtained and submitted before applying for occupation certificate.
  4. That 10 ft. wide paved pathway upto staircase will not be provided.
  5. That the surrounding open spaces, parking spaces and terrace will not be kept open and un-built upon and will not be leveled and developed before requesting to grant permission to occupy the building or submitting the B.C.C. whichever is earlier.
  6. That the name plate/board showing plot No. name of the building etc. will not be displayed at a prominent place before O.C.C./B.C.C.
  7. That the parking spaces shall not be provided as per D.C.Regulation No.36.
  8. That B.C.C. will not be obtained and I.O.D. and debris deposit etc. will not be claimed for refund within a period of 6 years from the date of its payment.
  9. That the provision will not be made for making available water for flushing and other non-potable purposes through a system of bore well and pumping that water through a separate overhead tank which will be connected to the drainage system and will not have any chances of mixing with the normal water supply of the Corporation.
  10. That the certificate to the effect that the licensed surveyor has effectively supervised the work and has carried out tests for checking leakages through sanitary blocks, termites, fixtures, joints in drainage pipes etc. and that the workmanship is found very satisfactory shall not be submitted.
  11. That one set of plans mounted on canvas will not be submitted.
  12. That the certificate from Lift Inspector regarding satisfactory installation and operation of lift will not be submitted.
  13. That the federation of flat owners of the sub-division/layout for construction and maintenance of the infrastructure will not be formed
  14. That the adequate provision for post-mail boxes shall not be made at suitable location on ground floor/stilt.
  15. That the every part of the building construction and more particularly, overhead tank will not be provided with a proper access for the staff of Insecticide Officer with a provision of temporary but safe and stable ladder etc.
  16. That the final NOC from S.G. shall not be submitted.

  
11/2/14  
Executive Engineer Building Proposat  
( Eastern Suburbs ) - II

**BRIHANMUMBAI MANDALAGAR PALIKA**  
**CE / S225 / BPES / AT 07 JUL 2014.**

17. That the infrastructural works such as; construction of hand-holes/manholes, ducts for underground cables, concealed wiring inside the flats/rooms, rooms/space for telecom installations etc. required for providing telecom services shall not be provided.
18. That the requisitions of clause No.45 & 46 of D.C.R.91 shall not be complied with.
19. That the provision for rain water harvesting as per design prepared by consultant in the field shall not be made to the satisfaction of Municipal Commissioner.
20. The owner shall submit to the Commissioner, a register undertaking agreeing to the conditions per the R 33(g) ii (a) to (d) of D.C.R.1991.
21. That the Vermiculture bins for disposal of wet waste as per the design and specification of organizations / individuals specialized in this field, as per the list furnished by Solid Waste Management Department of MCGM, shall not be provided to the satisfaction of Municipal Commissioner.
22. That as per Circular No.CHE/27921/OP/Gen dated 06/01/2014, the owner / developer and concerned architect / L.S. shall not compile and preserve the following documents :-  
a)Ownership document, b)Copies of IOD, CC subsequent amendments, O.C.C., B.C.C. and corresponding canvas mounted plans, c) copies of Soil Investigation Reports, d)RCC details and canvas mounted structural drawings, e) Structural Stability Certificate from Licensed Structural Engineer, f)Structural Audit Reports, g)All details of repairs carried out in the buildings, h) Supervision certificate issued by the Licensed Site Supervisor, i) Building Completion Certificate issued by L.S. / architect, j) NOC and completion certificate issued by the C.F.O., k)Fire Safety Audit carried out as per the requirement of C.F.O.

The above documents / plans shall not be handed over to the end user / prospective society within a period of 30 days in case of redevelopment of properties and in other cases, the same should not be handed over within a period of 90 days after granting Occupation Certificate.

**D) CONDITIONS TO BE COMPLIED WITH BEFORE B.C.C.**

1. That certificate under Section 270-A of the Bombay Municipal Corporation Act will not be obtained from H.E.'s department regarding adequacy of water supply.
2. That the ownership of the recreation space/Club House shall not vest by provision in a deed of conveyance in all the property owners on account of whose holding the R.G / Club House is assigned.
3. That the structure constructed in recreation space for the user of shall not be used only for recreational activity for which it is approved for the bonafide society members.

  
07/07/14  
**Executive Engineer**  
**(Building Proposals)E.S.II**


## NOTES

- (1) The work should not be started unless objections are complied with.
- (2) A certified set of latest approved plans shall be displayed on site at the time of commencement the work and during the progress of the construction work.
- (3) Temporary permission on payment of deposite should be obtained any shed to house and store for constructional purposes. Residence of workmen shall not be allowed on site. The temporary structures for storing constructional material shall be demolished before submission of building completion certificate and a certificate signed by Architect submitted along with the building completion certificate.
- (4) Temporary sanitary accommodation on full flushing system with necessary drainage arrangement should be provided on site workers, before starting the work.
- (5) Water connection for constructional purpose will not be given until the hoarding is constructed and application made to the Ward Officer with the required deposite for the construction of carriage entrance, over the road side drain, . . . .
- (6) The owners shall intimate the Hydraulic Engineer or his representative in Wards atleast 15 days prior to the date of which the proposed construction work is taken in hand that the water existing in the compound will be utilised for their construction works and they will not use any Municipal Water for construction purposes. Failing this, it will be presumed that Municipal tap water has been consumed on the construction works and bills preferred against them accordingly.
- (7) The hoarding or screen wall for supporting the depots of building materials shall be constructed before starting any work even though no materials may be expected to be stored in front of the property. The scaffolding, bricks metal, sand graps, debris, etc. should not be deposited over footpaths or public street by the owner/architect/their contractors, etc. without obtaining prior permission from the Ward Officer of the area.
- (8) The work should not be started unless the manner in obviating all the objection is approved by this department.
- (9) No work should be started unless the structural design is approved.
- (10) The work above plinth should not be started before the same is shown to this office Sub-Engineer concerned and acknowledgement obtained from him regarding correctness of the open spaces & dimension.
- (11) The application for sewer street connections, if necessary, should be made simultaneously with commencement of the work as the Municipal Corporation will require time to consider alternative site to avoid the excavation of the road an footpath.
- (12) All the terms and conditions of the approved layout/sub-division under No. of should be adhered to and complied with.
- (13) No Building/Drainage Completion Certificate will be accepted non water connection granted (except for the construction purposes) unless road is constructed to the satisfaction of the Municipal Commissioner as per the provision of Section 345 of the Bombay Municipal Corporation Act and as per the terms and conditions for sanction to the layout.
- (14) Recreation ground or amenity open space should be developed before submission of Building Completion Certificate.
- (15) The access road to the full width shall be constructed in water bound macadam before commencing work and should be complete to the satisfaction of Municipal Commissioner including asphalting lighting and drainage before submission of the Building Completion Certificate.
- (16) Flow of water through adjoining holding or culvert, if any should be maintained unobstructed.
- (17) The surrounding open spaces around the building should be consolidated in Concrete having broken glass pieces at the rate of 125 cubic meters per 10 sq. meters below payment.
- (18) The compound/wall or fencing should be constructed clear of the road widening line with foundation below level of bottom of road side drain without obstructing flow of rain water from adjoining holding before starting the work to prove the owner's holding.
- (19) No work should be started unless the existing structures proposed to be demolished are demolished.

- (20) This Intimation of Disapproval is given exclusively for the purpose of enabling you to proceed further in the arrangements of obtaining No Objection Certificate from the Housing Commissioner under Section 14(3)(H) of the Rent Act and in the event of your proceeding with the work either without an intimation about commencing the work under Section 347(1)(aa) or your starting the work without removing the structures proposed to be removed the act shall be taken as a severe breach of the conditions under which this Intimation of Disapproval is issued and the sanctioned will be revoked and the commencement certificate granted under Section 45 of the Maharashtra Regional and Town Planning Act, 1966, (12 of the Town Planning Act), will be withdrawn.
- (21) If it is proposed to demolish the existing structures by negotiations with the tenants, under the circumstances, the work as per approved plans should not be taken up in hand unless the City Engineer is satisfied with the following :-
- Specific plans in respect of evicting or rehousing the existing tenants on hour stating their number and the area in occupation of each.
  - Specifically signed agreement between you and the existing tenants that they are willing to avail of the alternative accommodation in the proposed structure at standard rent.
  - Plans showing the phased programme of construction has to be duly approved by this office before starting the work so as not to contravene at any stage of construction, the Development control Rules regarding open spaces, light and ventilation of existing structure.
- (22) In case of extension to existing building, blocking of existing windows of rooms deriving light and its from other sides should be done first before starting the work.
- (23) In case of additional floor no work should be start or during monsoon which will cause arise water leakage and consequent nuisance to the tenants staying on the floor below.
- (24) the bottom of the over hand storage work above the finished level of the terrace shall not be more than 1 metre.
- (25) The work should not be started above first floor level unless the No Objection Certificate from the Civil Aviation Authorities, where necessary is obtained.
- (26) It is to be understood that the foundations must be excavated down to hard soil.
- (27) The positions of the Naharis and other appurtenances in the building should be so arranged as not to necessitate the laying of drains inside the building.
- (28) The water arrangement must be carried out in strict accordance with the Municipal requirements.
- (29) No new well, tank, pond, cistern or fountain shall be dug or constructed without the previous permission in writing of the Municipal Commissioner for Greater Mumbai, as required in Section 381-A of the Municipal Corporation Act.
- (30) All gully traps and open channel drains shall be provided with right fitting mosquito proof covers made of wrought iron plates or hinges. The manholes of all jisters shall be covered with a properly fitting mosquito proof hinged cast iron cap over in one piece, with locking arrangement provided with a bolt and hinge screwed on lightly serving the purpose of a lock and the warning pipes of the ribbet pretressed with screw or dome shape pieces (like a garden mari rose) with copper pipes with perforations each not exceeding 1.5 mm. in diameter. the cistern shall be made easily, safety and permanently a feasible by providing a firmly fixed iron ladder, the upper ends of the ladder should be earmarked and extended 40 cms. above the top where they are to be fixed at its lower ends in cement concrete blocks.
- (31) No broken bottles should be fixed over boundary walls. This prohibition refers only to broken bottles and not to the use of plane glass for coping over compound wall.
- (32) (a) Louvres should be provided as required by Bye-law No. 5 (b).  
(b) Lintels or Arches should be provided over Door and Window opening.  
(c) The drains should be laid as require under Section 234-I (a).  
(d) The inspection chamber should be plastered inside and outside.
- (33) If the proposed addition is intended to be carried out on old foundations and structures, you will do so at your own risk.

Copy to owner

M/S. Nayan Builders,  
C.A. - the owners



Executive Engineer, Building Proposals  
Zones E.S.-A 'T' Wards.

### PROFORMA - A

A) AREA STATEMENT		SQ.MTS.
1	Area of Plots per P. R. Card	3849.00
2	Deductions for:	
a)	Road Setback Area	273.93
b)	Proposed Road	—
c)	Any Reservation (Railway Reservation)	—
d)	—%amently space as per DCR 35(7) (sub-plot)	—
	Total Deductions (a+b+c)	273.93
3	Balance Area of Plot (1-2)	3575.07
4	Deduction for Reservation Ground (If Deductable) 15%	536.26
5	Net Plot Area (3-4)	3038.81
6	Additions for Floor Space Index	
2(e)	100% Set Back Area	—
2(b)	100% DP.Road	—
7.	Total Area (5+6)	3038.81
8	Floor Space Index Permissible	ONE
9	9(a)Floor Space index Credit available by Development Rights	—
	Additions for floor space index:	
9(b)	Additional F. S. I. 0.33 as per Notification No. TPB - 4308 / 776 / CR - 127 / 2008 / LD - 11 DT. 24/10/2011 Premium amount of Rs. —/- paid to M. C. G. M. under receipt No. —/- dt. —/- paid to State Government (R.B.I.) under receipt No. —/- dt. —/-	—
9(c)	% as per DCR 33 ( )	—
9(d)	Other	—
10	Permissible Floor Area (7 x 8) + 9 above	3038.81
11	Existing Floor Area	—
12	Proposed Built up Area	3023.60
13	Excess Below area taken in Floor Space Index	—
14(A)	Purely Residential Built up area	3023.60
14(B)	Remaining Non-Residential Built up area	—
14(C)	TOTAL Built up proposed (11+12+13) (as per old approved plan d) —/— prior to 06/01/12	3023.60
15	Floor Space Index consumed	14/3 0.84

### BUILT- UP AREA SUMMARY

FLOORS	TOTAL B.U. AREA (WING-A) SQ.MTS	TOTAL B.U. AREA (WING-B) SQ.MTS	TOTAL B.U. AREA (WING-C) SQ.MTS	TOTAL B.U. AREA (WING-A+B+C) SQ.MTS
GR.FL.	—	—	—	—
1ST F.L.	311.07	—	219.70	530.77
2ND F.L.	311.07	277.87	219.70	800.64
3RD F.L.	311.07	277.87	219.70	800.64
4TH F.L.	257.47	277.87	219.70	755.04
EXCLOSURE AREA OF SITE 15/18 CENTER	—	—	—	120.51
TOTAL	1190.68	833.61	878.60	3023.60
				TOTAL GROSS BUILT-UP AREA = 3023.60 SQ. MT.

### STAIRCASE AREA STATEMENT

FLOORS	TOTAL AREA (WING-A) SQ.MTS	TOTAL AREA (WING-B) SQ.MTS	TOTAL AREA (WING-C) SQ.MTS	TOTAL AREA (WING-A+B+C) SQ.MTS
GR.FL.	—	—	—	—
1ST F.L.	35.40	35.40	35.44	106.24
2ND F.L.	35.40	35.40	35.44	106.24
3RD F.L.	35.40	35.40	35.44	106.24
4TH F.L.	35.40	35.40	35.44	106.24
TOTAL	141.60	141.60	141.76	424.96
				TOTAL GROSS BUILT-UP AREA = 424.96 SQ. MT.

### CAR PARKING STATEMENT

AS PER PRESENT REGULATION

CARPET AREA (SQ.MT)	REG. PARKING AS PER D.C.R. RULE	NO. OF FLATS	REQ. PARKING
BELLOW 95.00	1 PARK / 2 TENN.	—	NIL
36.00 TO 45.00	1 PARK / 2 TENN.	94 NOS.	92.00 NOS.
45.00 TO 70.00	1 PARK / 2 TENN.	13 NDS.	13.00 NOS.
ABOVE 70.00	1 PARK / 2 TENN.	22 NOS.	44.00 NOS.
TOTAL		39 NOS.	59.00 NOS.
25 % ADDITIONAL PARKING FOR VISITORS		14.75 NOS.	
Y.O.TAL.		73.75 NOS.	
PARKING REQUIRED =		74.00 NOS.	
TOTAL PARKING PROVIDED =		95.00 NOS.	

### B) Details of FSI available as per DCR 35(4)

- Fungible Built Up Area component proposed vide DCR 35(4) for purely residential = 144 x 0.35 =
- Fungible Built Up Area component proposed vide DCR 35(4) for Non-residential = 148 x 0.20
- Total fungible Built Up Area vide DCR 35(4) = (B.1 + B.2)
- Total Gross BUILT-UP AREA permissible (14+ B.3) 3038.81
- Total Gross BUILT-UP AREA proposed 3023.60

### C) Tenement Statement

- Proposed Area (item 12 above) 3023.60
- Less Non Residential Area (Bank) —
- Area Available for Tenements (i-ii) 3023.60
- Tenements Permissible Density of Tenements 450/Hec 136 Nos.
- Tenements Existing —
- Total Tenements on the Plot 39 Nos.

### D) PARKING AREA STATEMENT

- Parking Required by Regulation 49 74 Nos.
- Covered Garages Permissible —
- Covered Garages Proposed —
- Total Parking Provided 95 Nos.

### E) Transport Vehicles Parking

- Space for Transport vehicles parking required by Regulation —
- Total no. of transport vehicles parking spaces provided —

### PROFORMA-B

#### CONTENT OF SHEET

GROUND FLOOR PLAN; BUILT UP AREA SUMMARY; STAIRCASE AREA STATEMENT; PLOT AREA CALCULATION; PARKING AREA STATEMENT; BLOCK & LOCATION PLAN.

STAMP OF DATE OF RECEIPT OF PLAN STAMP OF APPROVAL OF PLAN

07 JUL 2014  
Approved subject to the conditions mentioned  
In this office Letter No./CE/ 52-25/BPS/AT

Executive Engineer Bldg. Prop. (E.S.) —/—

M/S. NAYAN BUILDERS C. A. TO OWNER

JOB NO. DRG. NO. DATE DRN. BY CHK. BY REVISION


1/4 SHASHI ASHISH

NAME SIGNATURE & ADDRESS OF LICENSED SURVEYOR

ASHISH BHATT

SHOP NO. 6, BASEMENT GROUND FLOOR,  
RURAL COMMERCIAL COMPLEX,  
NEXT TO SANTOSH MATA TEMPLE,  
MULUND (WEST), MUMBAI - 400080

### LOCATION PLAN



LOCATION PLAN


SCALE : 1:4000



### PLOT AREA CALCULATION

ADDITIONS :	
1 .	61.12 X 29.88 X 0.50 NOS. = 913.13 SQ.MT.
2 .	63.11 X 5.98 X 0.50 NOS. = 188.70 SQ.MT.
3 .	71.92 X 10.54 X 0.50 NOS. = 379.02 SQ.MT.
4 .	86.41 X 18.56 X 0.50 NOS. = 801.88 SQ.MT.
5 .	87.41 X 0.85 X 0.50 NOS. = 37.15 SQ.MT.
6 .	87.89 X 2.82 X 0.50 NOS. = 123.92 SQ.MT.
7 .	88.75 X 2.49 X 0.50 NOS. = 110.49 SQ.MT.
8 .	88.98 X 1.12 X 0.50 NOS. = 49.83 SQ.MT.
9 .	100.04 X 21.90 X 0.50 NOS. = 1095.44 SQ.MT.
10 .	102.23 X 4.88 X 0.50 NOS. = 249.44 SQ.MT.
	TOTAL PLOT AREA = 3949.00 SQ.MT.

### PLOT AREA LINE DIAGRAM



PLOT AREA LINE DIAGRAM

SCALE : 1:200

### R. G. AREA LINE DIAGRAM

### R. G. AREA CALCULATION

ADDITIONS :	
1 .	8.22 X 5.85 X 0.50 NOS. = 24.04 SQ.MT.
2 .	8.22 X 3.26 X 0.50 NOS. = 13.40 SQ.MT.
3 .	10.97 X 4.64 X 0.50 NOS. = 25.49 SQ.MT.
4 .	10.97 X 3.17 X 0.50 NOS. = 17.39 SQ.MT.
5 .	3.42 X 2.54 X 0.50 NOS. = 4.34 SQ.MT.
6 .	3.35 X 1.50 X 0.50 NOS. = 2.18 SQ.MT.
7 .	14.45 X 0.91 X 0.50 NOS. = 6.57 SQ.MT.
8 .	23.40 X 5.53 X 0.50 NOS. = 64.70 SQ.MT.
9 .	3.90 X 1.62 X 0.50 NOS. = 3.16 SQ.MT.
10 .	11.07 X 1.49 X 0.50 NOS. = 8.25 SQ.MT.
11 .	2.90 X 1.50 X 0.50 NOS. = 2.32 SQ.MT.
12 .	7.27 X 2.07 X 0.50 NOS. = 7.52 SQ.MT.
13 .	5.13 X 2.37 X 0.50 NOS. = 6.08 SQ.MT.
14 .	4.26 X 4.04 X 1 NOS. = 17.21 SQ.MT.
15 .	1.66 X 1.83 X 1 NOS. = 3.07 SQ.MT.
16 .	10.98 X 6.07 X 0.50 NOS. = 33.22 SQ.MT.
17 .	10.98 X 2.17 X 0.50 NOS. = 11.91 SQ.MT.
18 .	8.33 X 2.61 X 0.50 NOS. = 10.87 SQ.MT.
19 .	8.42 X 2.43 X 0.50 NOS. = 10.23 SQ.MT.
20 .	26.68 X 7.24 X 0.50 NOS. = 96.58 SQ.MT.
21 .	23.93 X 24.15 X 0.50 NOS. = 288.95 SQ.MT.
22 .	25.77 X 4.48 X 0.50 NOS. = 57.72 SQ.MT.
	TOTAL R. G. AREA = 715.26 SQ.MT.




### GROUND FLOOR PLAN

## &lt;h3


07 JUL 2014

Approved subject to the conditions mentioned  
in this office Letter No.CE/5225 APESIA/T*Chaitanya*  
Executive Engineer Bldg. Prop. (E/S) I-II

S.E.(B.P.)TW




PROFORMA-B					
CONTENT OF SHEET					
1ST PODIUM FLOOR PLAN, SECTION A-A & B-B			STAMP OF DATE OF RECEIPT OF PLAN		
			STAMP OF APPROVAL OF PLAN		
			<p>गृहालय अधिकारी का संकेत, उन ग्रामीण अधिकारी का संकेत (प्रदीप अमरलाल) मार्च 2014</p> <p>30 JUN 2014</p> <p>गृहालय/वीडी /</p>		
DESCRIPTION OF PROPOSAL					
PROPOSED REDEVELOPMENT ON PLOT BEARING C.T.S. NO. 1391, 1391/1 TO 17 OF VILLAGE MULUND (W), OFF J.N. ROAD MULUND (W), MUMBAI					
NAME AND SIGNATURE OF OWNER					
<p><i>[Signature]</i></p> <p>M/S NAYAN BUILDERS C.A. TO OWNER</p>					
JOB NO.	DRG. NO.	DATE	DRN. BY	CHK. BY	REVISION
100	2/4		ASHISH	ASHISH	
NAME SIGNATURE & ADDRESS OF LICENSED SURVEYOR					
<p><i>[Signature]</i></p> <p>ASHISH BHATT SHOP NO. 6, GASHIM GROUND FLOOR, RUNWAL COMMERCIAL COMPLEX, NEXT TO SANTOSHI MATA TEMPLE, MULUND (WEST), MUMBAI - 400080.</p>					



07 JUL 2014  
Approved subject to the conditions mentioned  
in this office Letter No./OEB/5225/BPEIA

Executive Engineer Bldg. Prop. (E.S.)  
S.E.(B.P.) T/W



TERRACE FLOOR PLAN

SCALE: 1:100

CARPET AREA STATEMENT

FLAT NO. 1 WING - 'A' (1ST TO 4TH FLOOR)

	ADDITIONS:		
1 LIVING RM.	5.66 X 4.66 X 1 NOS. =	16.32	SQ.MT.
3.20 X 2.94 X 1 NOS. =	9.43	SQ.MT.	
2 PASSAGE	2.89 X 1.20 X 1 NOS. =	3.47	SQ.MT.
3.20 X 1.05 X 1 NOS. =	3.36	SQ.MT.	
1.80 X 1.35 X 1 NOS. =	2.43	SQ.MT.	
3 KITCHEN	3.35 X 3.05 X 1 NOS. =	20.22	SQ.MT.
6 BED RM.	4.28 X 3.35 X 1 NOS. =	14.34	SQ.MT.
1.65 X 0.90 X 1 NOS. =	1.49	SQ.MT.	
8 BED RM.	3.05 X 2.95 X 1 NOS. =	12.08	SQ.MT.
10 BED RM.	4.73 X 3.20 X 1 NOS. =	15.14	SQ.MT.
11 TOILET	1.50 X 2.30 X 1 NOS. =	3.45	SQ.MT.
12 TOILET	2.45 X 1.35 X 1 NOS. =	6.02	SQ.MT.
13 D	1.05 X 0.15 X 1 NOS. =	0.16	SQ.MT.
14 D1	0.15 X 0.90 X 4 NOS. =	0.54	SQ.MT.
15 D2	0.15 X 0.75 X 3 NOS. =	0.34	SQ.MT.
16 DP.	1.20 X 0.15 X 1 NOS. =	0.18	SQ.MT.
TOTAL ADDITIONS	=	99.55	SQ.MT.

FLAT NO. 1 WING - 'D' (1ST TO 4TH FLOOR)

	ADDITIONS:		
1 LIVING RM.	3.20 X 6.03 X 1 NOS. =	19.80	SQ.MT.
1.52 X 2.08 X 1 NOS. =	3.13	SQ.MT.	
2 DINNING	2.71 X 2.93 X 1 NOS. =	6.73	SQ.MT.
3 PASSAGE	1.50 X 1.32 X 1 NOS. =	1.98	SQ.MT.
4 KITCHEN	3.33 X 3.95 X 1 NOS. =	12.82	SQ.MT.
5 BED RM.	3.05 X 4.11 X 1 NOS. =	12.54	SQ.MT.
6 BED RM.	4.05 X 3.35 X 1 NOS. =	14.18	SQ.MT.
7 TOILET	1.37 X 2.30 X 2 NOS. =	6.07	SQ.MT.
8 TOILET	1.05 X 0.15 X 1 NOS. =	0.16	SQ.MT.
9 D	1.05 X 0.15 X 1 NOS. =	0.15	SQ.MT.
10 D1	0.15 X 0.90 X 3 NOS. =	0.45	SQ.MT.
11 D2	0.15 X 0.75 X 2 NOS. =	0.23	SQ.MT.
12 DP.	0.15 X 0.92 X 1 NOS. =	0.14	SQ.MT.
TOTAL ADDITIONS	=	74.72	SQ.MT.

FLAT NO. 1 WING - 'C' (1ST TO 4TH FLOOR)

	ADDITIONS:		
1 LIVING RM.	3.75 X 4.95 X 1 NOS. =	18.56	SQ.MT.
2 PASSAGE	0.90 X 1.50 X 1 NOS. =	1.35	SQ.MT.
3 DINNING	3.35 X 2.60 X 1 NOS. =	8.71	SQ.MT.
4 KITCHEN	2.75 X 3.35 X 1 NOS. =	9.21	SQ.MT.
5 BED RM.	3.20 X 3.81 X 1 NOS. =	12.19	SQ.MT.
6 BED RM.	3.35 X 4.57 X 1 NOS. =	15.31	SQ.MT.
7 TOILET	2.30 X 1.50 X 1 NOS. =	3.45	SQ.MT.
8 TOILET	2.45 X 1.50 X 1 NOS. =	3.68	SQ.MT.
9 D	1.05 X 0.15 X 1 NOS. =	0.16	SQ.MT.
10 D1	0.15 X 0.90 X 3 NOS. =	0.45	SQ.MT.
11 D2	0.15 X 0.75 X 2 NOS. =	0.23	SQ.MT.
12 DP.	0.15 X 0.95 X 1 NOS. =	0.14	SQ.MT.
TOTAL ADDITIONS	=	73.40	SQ.MT.

FLAT NO. 1 WING - 'B' (1ST TO 4TH FLOOR)

	ADDITIONS:		
1 LIVING RM.	3.66 X 4.37 X 1 NOS. =	16.99	SQ.MT.
3.20 X 2.08 X 1 NOS. =	6.66	SQ.MT.	
2 DINNING	2.25 X 2.91 X 1 NOS. =	6.55	SQ.MT.
3 KITCHEN	3.35 X 2.75 X 1 NOS. =	9.21	SQ.MT.
4 BED RM.	3.05 X 3.95 X 1 NOS. =	12.05	SQ.MT.
5 BED RM.	4.05 X 3.35 X 1 NOS. =	13.57	SQ.MT.
6 BED RM.	1.37 X 2.30 X 2 NOS. =	6.30	SQ.MT.
7 TOILET	1.05 X 0.15 X 1 NOS. =	0.16	SQ.MT.
8 TOILET	1.05 X 0.15 X 1 NOS. =	0.15	SQ.MT.
9 D	1.05 X 0.15 X 1 NOS. =	0.15	SQ.MT.
10 D1	0.15 X 0.90 X 3 NOS. =	0.45	SQ.MT.
11 D2	0.15 X 0.75 X 2 NOS. =	0.23	SQ.MT.
12 DP.	0.15 X 0.90 X 1 NOS. =	0.14	SQ.MT.
TOTAL ADDITIONS	=	74.84	SQ.MT.

	ADDITIONS:		
1 LIVING RM.	6.38 X 2.60 X 1 NOS. =	16.61	SQ.MT.
3.35 X 3.15 X 1 NOS. =	10.55	SQ.MT.	
2 PASSAGE	1.30 X 1.05 X 1 NOS. =	1.37	SQ.MT.
3 KITCHEN	2.45 X 3.65 X 2 NOS. =	8.94	SQ.MT.
4 BED RM.	3.35 X 4.10 X 1 NOS. =	13.74	SQ.MT.
5 BED RM.	3.35 X 4.65 X 1 NOS. =	15.58	SQ.MT.
6 TOILET	1.37 X 2.30 X 2 NOS. =	6.30	SQ.MT.
7 D	1.00 X 0.15 X 1 NOS. =	0.15	SQ.MT.
8 D1	0.35 X 0.90 X 3 NOS. =	0.45	SQ.MT.
9 D2	0.15 X 0.76 X 2 NOS. =	0.23	SQ.MT.
TOTAL ADDITIONS	=	74.84	SQ.MT.

FITNESS CENTER LINE DIAGRAM

1ST FLOOR  
SCALE: 1:100

FITNESS CENTER AREA CALCULATIONS

ADDITIONS:			
1 LIVING RM.	3.95 X 2.55 X 1 NOS. =	10.07	SQ.MT.
3.05 X 1.90 X 1 NOS. =	5.80	SQ.MT.	
1.30 X 1.05 X 1 NOS. =	1.37	SQ.MT.	
2 PASSAGE	0.90 X 1.20 X 1 NOS. =	1.09	SQ.MT.
3 KITCHEN	2.45 X 3.25 X 1 NOS. =	7.96	SQ.MT.
4 BED RM.	3.95 X 3.00 X 1 NOS. =	12.05	SQ.MT.
5 TOILET	2.15 X 1.20 X 2 NOS. =	5.16	SQ.MT.
6 D	1.00 X 0.15 X 1 NOS. =	0.15	SQ.MT.
7 D1	0.13 X 0.99 X 2 NOS. =	0.27	SQ.MT.
8 D2	0.15 X 0.76 X 2 NOS. =	0.23	SQ.MT.
TOTAL ADDITIONS	=	44.14	SQ.MT.

PERMISSIBLE AREA FOR FITNESS CENTER = 2% OF 2903.09 = 58.06 sq.m.  
PROPOSED AREA OF FITNESS CENTER = 178.57 sq.m.  
EXCESS AREA TO BE COUNTED IN F.S.I. = 178.57 - 58.06 = 120.51

REDEVELOPMENT ON PLOT BEARING C.T.S. NO. 1381, 1381/1 TO 17  
OF VILLAGE MULUND (W), OFF J. N. ROAD MULUND (W), MUMBAI  
NAME AND SIGNATURE OF OWNER

M/S NAYAN BUILDERS C. A. TO OWNER

JOB NO. DRG. NO. DATE DRN. BY CMK. BY REVISON  
4/4 SHASHI ASHISH

NAME SIGNATURE & ADDRESS OF LICENSED SURVEYOR

ASHISH BHATT  
SHOP NO. 6, BASEMENT GROUND FLOOR,  
BUNWAL COMMERCIAL COMPLEX,  
NEXT TO SANTOSH MATA TEMPLE,  
MULUND (WEST), MUMBAI - 400080